

TEST CERTIFICATE

Doc Ref: SADS-IMS-FM-92

Issue 01

Issue Date: 28/05/2020

Issued By: P. Curtis

TYPE OF TEST / INSPECTION	Dive Control Continuity and Resistance Test
CERTIFICATE NUMBER	SADS-FGV-020
ITEM LOCATION	DSV Curtis Marshall
SADS ID	SADS-DSV-DC-ELEC

TEST INSPECTION RESULTS

Component	Insulation Resistance @ 500v	Continuity	Remarks
DC Power			
1-16	1378Ω		
4-13	>2000Ω		
5-14	>2000Ω		
6-15	>2000Ω		
DC Comms			
3-24	>1581Ω		
4-7	>2000Ω		
5-8	>2000Ω		
6-22	>2000Ω		
Rack system			
4-1	>2000Ω		
5-2	>2000Ω		
UPS			
1-10	>2000Ω		
3-1	>2000Ω		
4-7	>2000Ω		
5-8	>2000Ω		

REMARKS / RECOMMENDATIONS

Note No =Wires labelled with tags outside of DC

Annual electrical inspection of dive control electrical system including UPS.

DATE OF INSPECTION

15th Oct 2024

NEXT DUE DATE:

14th Oct 2025

TEST CERTIFICATE

Doc Ref: SADS-IMS-FM-92

Issue 01


Issue Date: 28/05/2020


Issued By: P. Curtis

TECHNICIAN NAME: A. A. NORRIS

TECHNICIAN SIGNATURE:

A. A. Norris

 Sub Aqua Diving Services	Tech Dept _____
---	--------------------



Sub Aqua
Diving Services (UK) Ltd