

ELECTRICAL INSTALLATION CERTIFICATE

REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS 7671 (IEE Wiring Regulations)

Page 1 of 5

CERT No. DSV 01

CLIENT DETAILS

B. MARSHALL MARINE LTD.

INSTALLATION ADDRESS

D.S.V. CURTISS - MARSHALL (DIVE Support Vessel)

DESCRIPTION AND EXTENT OF THE INSTALLATION

✓ tick boxes as appropriate

New installation ☒ Addition to an existing installation ☐ Alteration to an existing installation ☐

Description of installation: LEVEL 1 240V DISTRIBUTION SYSTEM (IN DIVE CONTROL)

Extent of installation work covered by this certificate: DISTRIBUTION BOARD No.1 (DIVE CONTROL)

DESIGN

I/We* being the person(s) responsible for the design of the electrical installation (as indicated by my/our* signature(s) below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design hereby CERTIFY that the design work for which I/we* have been responsible is to the best of my/our* knowledge and belief in accordance with BS 7671: 2008 amended to (date) except for the departure(s), if any, details as follows:

Details of departure(s) from BS 7671:

NONE

The extent of liability of the signatory or the signatories is limited to the work described above as the subject of this certificate.

For the DESIGN of the installation:
Designer (No.1) - Signature *C. Jakeman* Name (BLOCK LETTERS) C. JAKEMAN Date 2nd/5/2014
Designer (No.2) - Signature *A. E. Norris* Name (BLOCK LETTERS) A. NORRIS Date 2nd/5/2014

CONSTRUCTION

I/We* being the person(s) responsible for the construction of the electrical installation (as indicated by my/our* signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the construction hereby CERTIFY that the construction work for which I/we* have been responsible is to the best of my/our* knowledge and belief in accordance with BS 7671: 2008 amended to (date) except for the departure(s), if any, details as follows:

Details of departure(s) from BS 7671:

NONE

The extent of liability of the signatory or the signatories is limited to the work described above as the subject of this certificate.

For the CONSTRUCTION of the installation:
Constructor(s) - Signature(s) *A. E. Norris* Name(s) (BLOCK LETTERS) A. NORRIS Date 17/5/2014

INSPECTION & TESTING

I/We* being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our* signature(s) below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby CERTIFY that the inspection and testing work for which I/we* have been responsible is to the best of my/our* knowledge and belief in accordance with BS 7671: 2008 amended to (date) except for the departure(s), if any, details as follows:

Details of departure(s) from BS 7671:

NONE

The extent of liability of the signatory or the signatories is limited to the work described above as the subject of this certificate.

For the INSPECTION AND TESTING of the installation:
Inspector(s) - Signature(s) *A. E. Norris* Name(s) (BLOCK LETTERS) A. NORRIS Date 11/01/2015

NEXT INSPECTION

I/We* the designer(s), recommend that this installation is further inspected and tested after an interval of not more than

YEARS 5 MONTHS 0

ELECTRICAL INSTALLATION CERTIFICATE

REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS 7671 (IEE Wiring Regulations)

CERT No. **DSV 01**

Page 2 of **5**

DESIGNER (No.1)

Name: **C. JAKEMAN.**
Company: **B. MARSHALL MARINE LTD**
Address: **DOCKSIDE ROAD,**
MIDDLESBROUGH
Postcode: **TS38AT** Phone No: **01642-21234**

DESIGNER (No.2)

Name: **A. NORRIS**
Company: **YARM ELECTRICAL SERVICES**
Address: **29 ROUNDHAY DRIVE**
EAGLESCUFFE.
Postcode: **TS16 9HW** Phone No: **01642-787502**

CONSTRUCTOR(S)

Name(s): **A. NORRIS**
Company: **YARM ELECTRICAL SERVICES**
Address: **29 ROUNDHAY DRIVE,**
EAGLESCUFFE.
Postcode: **TS16 9HW** Phone No: **01642-787502**

INSPECTOR(S)

Name(s): **A. NORRIS**
Company: **YARM ELECTRICAL SERVICES**
Address: **29 ROUNDHAY DRIVE,**
EAGLESCUFFE.
Postcode: **TS16 9HW** Phone No: **01642-787502**

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

✓ tick box where applicable

Number of Live Conductors 2/3/4*	Type of live conductors: a.c. / d.c. *	
Nature of Supply	Nominal voltage: U 238 (V) U ₀ _____ (V)	Nominal frequency (f): 50 Hz
	Fault current (earth fault/short-circuit)*: 0.42 A	External loop impedance (Z _e): 0.71 Ω
Supply Protective Device Characteristics:	BS (EN): 88 FUSE	Rated Current/Current Setting (In) 80 A
Earthing Arrangements:	TN-S <input checked="" type="checkbox"/> TN-CS <input type="checkbox"/> TT <input type="checkbox"/> TN-C <input type="checkbox"/> IT <input type="checkbox"/>	

PARTICULARS OF INSTALLATION REFERRED TO IN THE CERTIFICATE

Maximum demand (load): **80** ~~kVA~~ / Amps per phase

Means of Earthing: Distributor's facility ☒ Installation earth electrode ☐

Details of Installation Earth Electrode

Location: _____ Type (rods, etc.): _____

Electrode Resistance to Earth (R_e): _____ Ω Method of Measurement: _____

Main Protective Conductors

Earthing Conductor:	Material: Copper c.s.a: 16.0 mm ²	Connection(s) verified: <input checked="" type="checkbox"/>
Protective Bonding Conductors:	Material: Copper c.s.a: 16.0 mm ²	Connection(s) verified: <input checked="" type="checkbox"/>

To: Water Installation Pipe ☐ Gas Installation Pipe ☐ Other Elements ☒ **STRUCTURE : 16.0 mm**

Main Switch or Circuit-breaker

Location: _____ BS (EN), type and No. of poles **60947-3(2)** Current rating: **100** A Fuse rating or setting: **80A.** Voltage rating: **400** V

Rated residual operating current I_{Δn}: _____ mA Operating time at I_{Δn}: _____ ms

COMMENTS ON EXISTING INSTALLATION

SCHEDULE(S)

THE ATTACHED SCHEDULES ARE PART OF THIS DOCUMENT AND THIS CERTIFICATE IS VALID ONLY WHEN THEY ARE ATTACHED TO IT.

No. of Schedules of Inspections attached: **1** No. of Schedules of Test Results attached: **1**

This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed and inspected and tested in accordance with BS 7671: 2008 (the IEE Wiring Regulations).

The recipient should receive the 'original' certificate and a duplicate should be retained by the contractor. In the event that you are the person ordering or acting on behalf of the owner, this certificate or a copy of it should be passed to the owner immediately. The 'original' certificate should be kept in a safe place and should be

shown to any person carrying out work on or inspecting this installation in the future.

For safety reasons this electrical installation needs to be re-inspected by a competent person at appropriate intervals. Under the section 'Next Inspection' of this certificate it states the maximum time interval recommended before the next inspection.

The Construction (Design and Management) Regulations require for an installation covered by those Regulations, that a copy of this

certificate together with the relevant schedules of inspection and test results are included in the project health and safety documentation.

This certificate is only intended to be issued for a new installation or for new work carried out on or associated with the alteration or addition to an existing installation.

Location: **D.S.V. CURTIS - MARSHALL** Date: **01/2015**

Designation: **D.B. NO 1. UPPER ACCOMMODATION LEVEL (DIVE CONTROL)**

Inspected and tested by: (Print and sign) **A. NORRIS**

Name: **A. NORRIS**

Signature: **[Signature]**

System Characteristics

System type: ☐ TN-S ☐ TT ☐ Fault level(s):

1 ϕ **0.42** kA

3 ϕ **0.71** kA

Measured impedance at dis. board/consumer unit Z_0/Z_B : **0.71** Ω

Main Switch Supply polarity confirmed: ☒ (V)

Make: **C.I.D.G.** BS (EN): **60947-3**

Voltage rating: **400 V** Current rating (I_n): **100 A**

(If) RCD: **ms** Operation time (at $I_{\Delta n}$): **ms**

DB/CU supplied from: **MAIN CONTROL**

PANEL FUSED @ 80A TO BS 88

Supply Protective Device Details

BS (EN): **88** Current rating (I_n): **80 A** (If) RCD: **ms** Operating time at $I_{\Delta n}$: **ms**

CIRCUIT DETAILS													TEST RESULTS								
Number of ways	Circuit description	Type of wiring (e.g. PVC/PVC)	Number of points served	Circuit conductors (mm ²)		Max disconnection time (s) permitted by BS 7671	Overcurrent protective devices			RCD Opening current I _{an} (mA)	Circuit impedances (Ω)				Insulation resistance (MΩ)	Polarity (V)	Maximum measured earth fault loop impedance, Z _e (Ω)	RCD operating times (ms)			
				Live	CPC		BS (EN)	Type	Rating (A)		Fault current capacity (kA)	Ring final circuits only	All circuits R ₁ + R ₂ or R ₀	Between live conductors				Line(s)/Earth/Neutral/Earth	at I _{an}	at 5I _{an} (if applicable)	
1	GALLEY HOB	BTY	1	4.0	4.0		BS 61009	B	32	6	30				2200	2200	✓	0.77	20	5	
2	GALLEY SOCKETS	PVC/BY	6	2.5	2.5		BS 61009	B	32	6	30				2200	2200	✓	0.76	20	5	
3	DIVE CONTROL FRONT SOCKETS	PVC/BY	4	2.5	2.5		BS 61009	B	32	6	30				2200	2200	✓	0.77	21	6	
4	BEDROOMS SOCKETS	PVC/BY	7	2.5	2.5		BS 61009	B	32	6	30				2200	2200	✓	0.87	20	5	
5	FRIDGE / FREEZER POINT	PVC/BY	1	2.5	2.5		BS 61009	B	16	6	30				2200	2200	✓	0.83	22	6	
6	WASHING MACHINE	PVC/BY	1	2.5	2.5		BS 61009	B	16	6	30				2200	2200	✓	0.80	20	5	
7	TEA BOILER	PVC/BY	1	2.5	2.5		BS 61009	B	16	6	30				2200	2200	✓	0.81	20	5	
8	BEDROOM HEATER (No.1)	PVC/BY	1	1.5	1.5	0.4	BS 60898	B	10	6					2200	2200	✓	0.81			
9	BEDROOM LIGHTS	TQ/TN		1.0	1.0	0.4	BS 60898	B	6	6					≥	≥	✓				
10	GALLEY LIGHTS	TQ/TN	9	1.0	1.0	0.4	BS 60898	B	6	6					≥	≥	✓				
11	DIVE CONTROL EQUIP. SOCKET	PVC/BY	7	2.5	2.5	0.4	BS 60898	B	32	6					2200	2200	✓	0.74			
12	DIVE CONTROL HEATER	PVC/BY	1	1.5	1.5	0.4	BS 60898	B	16	6					2200	2200	✓	0.71			
TEST INSTRUMENTS USED		Make	Model	Multi-functional:	Serial Number													RCD:		KMP 540	
		ROBIN	KMP 3050		4121190													Earth fault loop impedance:		412.5859	
		Continuity:	KMP 3050		4121190													Earth electrode resistance:		412.5859	
		Insulation resistance:	ROBIN		4121190													Earth fault loop impedance:		412.5859	
			ROBIN		4121190													ROBIN		KMP 4120	
																		ROBIN		KMP 540	
																		ROBIN		336651	

D.S.V. Oil

TEST RESULTS

FURTHER COMMENTS/OBSERVATIONS:

SCHEDULE OF INSPECTIONS

Page **5** of **5**

CERT/REPORT
SCHEDULE NO

DSV 01

Methods of protection against electric shock

Both basic and fault protection:

- ☒ (i) SELV
- ☒ (i) PELV
- ☐ (iii) Double insulation
- ☒ (iv) Reinforced insulation

Basic protection:

- ☒ (i) Insulation of live parts
- ☒ (i) Barriers or enclosures
- ☒ (iii) Obstacles
- ☒ (iv) Placing out of reach

Fault protection

(i) Automatic disconnection of supply:

- ☒ Presence of earthing conductor
- ☒ Presence of circuit protective conductors
- ☒ Presence of protective bonding conductors
- ☒ Presence of supplementary bonding conductors
- ☒ Presence of earthing arrangements for combined protective and functional purposes
- ☒ Presence of adequate arrangements for alternative source(s), where applicable
- ☒ FELV
- ☒ Choice and setting of protective and monitoring devices (for fault and/or overcurrent protection)

(ii) Non-conducting location:

- ☒ Absence of protective conductors

(iii) Earth-free local equipotential bonding:

- ☒ Presence of earth-free local equipotential bonding

(iv) Electrical separation:

- ☒ Provided for **one** item of current-using equipment
- ☒ Provided for **more than one** item of current-using equipment

Additional protection:

- ☒ Presence of residual current device(s)
- ☒ Presence of supplementary bonding conductors

☒ To indicate an inspection has been carried out and the result is satisfactory.

Prevention of mutual detrimental influence

- ☒ (a) Proximity of non-electrical services and other influences
- ☒ (b) Segregation of Band I and Band II circuits or use of Band II insulation
- ☒ (c) Segregation of safety circuits

Identification

- ☒ (a) Presence of diagrams, instructions, circuit charts and similar information
- ☒ (b) Presence of danger notices and other warning notices
- ☒ (c) Labelling of protective devices, switches and terminals
- ☒ (d) Identification of conductors

Cables and conductors

- ☒ Selection of conductors for current-carrying capacity and voltage drop
- ☒ Erection methods
- ☒ Routing of cables in prescribed zones
- ☒ Cables incorporating earthed armour or sheath or run within an earthed wiring system, or otherwise adequately protected against nails, screws and the like
- ☒ Additional protection provided by 30 mA RCD for cables concealed in walls (where required in premises not under the supervision of a skilled or instructed person)
- ☒ Connection of conductors
- ☒ Presence of fire barriers, suitable seals and protection against thermal effects

General

- ☒ Presence and correct location of appropriate devices for isolation and switching
- ☒ Adequacy of access to switchgear and other equipment
- ☒ Particular protective measures for special installations and locations
- ☒ Connection of single-pole devices for protection or switching in line conductor(s) only
- ☒ Correct connection of accessories and equipment
- ☒ Presence of undervoltage protective devices
- ☒ Selection of equipment and protective measures appropriate to external influences
- ☒ Selection of appropriate functional switching devices

☒ To indicate an inspection is not applicable.

In addition to the above, the following notations may also be used when reporting on existing installations:

☒ To indicate an inspection has been carried out and the result is unsatisfactory.

Lim Indicates that, exceptionally, a limitation agreed with the person ordering the work prevented the inspection being carried out.

Inspected by (print and sign):

A. NORRIS *A. Norris*

Date:

11th / JAN / 2015