

6 MONTHLY VISUAL INSPECTION & FUNCTION CHECK

Doc Ref: SADS-IMS-FM-93

Issue 01

Issue Date: 18/06/2020

Issued By: P. Curtis

ITEM DESCRIPTION	Uninterrupted power supply
ITEM LOCATION	DSV Curtis Marshall, Dive Control
SADS ID	DSV-UPS-01- 02 & 03
CERT NO	DSV-DC-UPS-6M-08
SERIAL NO. / MODEL NO.	5551220T11154, 5551220T11181, 5551220T11182

Description of Test / Inspection.

Full visual inspection of units.

UPS's fully charged, then powered off to assess battery / inverter function.

New Internal batteries fitted December 2019

Remarks: Results

Visual examination - All Good.

UPS's stored power exceeded 1 hour on all units.

Recorded in line with 6 monthly cert.

References:

IMCA D018- 11

IMCA D023. Sheet 2- Dive Control. Item 9.5

Once completed return to Document Controller to be uploaded and filed

DATE OF INSPECTION	05 th March 2025	NEXT DUE DATE:	04 th Sept 2025
--------------------	-----------------------------	----------------	----------------------------

TECHNICIAN NAME: Dan Zapalski/Derek Curtis

TECHNICIAN SIGNATURE: 

