



# EQUIPMENT MAINTENANCE RECORD

Date Issued: 14-02-2014	Make: APC Smart UPS 1500	
Description: Uninterruptible Power Supply	Prefix Other: SAD 03 UPS	MDS Ref No:
Serial No: 5S51220T11182	Hours Run:N/A	
Last Job Site: Sub Aqua Diving	Period of Validity:3 & 6 Months	
<b>Work to be carried out:</b>  <p style="text-align: center;">To include run down and recharge batteries</p> <p style="text-align: center;">Visual Inspection and Function test</p>		
<b>Equipment used Testing:</b>		
<b>Work carried:</b>  <p style="text-align: center;">To include run down and recharge batteries</p> <p style="text-align: center;">Visual Inspection and Function Test <input checked="" type="checkbox"/></p>		
<b>Comments:</b> Exceeded 30mins		
<b>Test Results:</b>  <div style="display: flex; justify-content: space-around;"> <span><input checked="" type="checkbox"/> PASSED</span> <span><input type="checkbox"/> FAILED</span> </div>		
<b>Technician:</b>    <div style="display: flex; justify-content: space-between; margin-top: 20px;"> <div>Date: 14/02/14</div> <div>Signed: </div> <div>Print Name: </div> </div>		