


EQUIPMENT MAINTENANCE RECORD

Date Issued: 14-02-2014	Make: APC Smart UPS 1500
Description: Uninterruptible Power Supply	Prefix Other: SAD 01 UPS MDS Ref No:
Serial No: 5S51220T11164	Hours Run:N/A
Last Job Site: Sub Aqua Diving	Period of Validity:3 & 6 Months
<p>Work to be carried out:</p> <p style="text-align: center;">To include run down and recharge batteries</p> <p style="text-align: center;">Visual Inspection and Function test</p>	
<p>Equipment used Testing:</p>	
<p>Work carried:</p> <p style="text-align: center;">To include run down and recharge batteries</p> <p style="text-align: center;">Visual Inspection and Function Test <input checked="" type="checkbox"/></p>	
<p>Comments: Exceeded 30 min's</p>	
<p>Test Results:</p> <p style="text-align: center;"><input checked="" type="checkbox"/> PASSED <input type="checkbox"/> FAILED</p>	
<p>Technician:</p> <p>Date: 14/02/14 Signed:  Print Name: M. Harrell</p>	