

ELECTRICAL INSTALLATION CERTIFICATE

REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS 7671 (IET Wiring Regulations)

Page 1 of

5

CERT No.

DSV 05**CLIENT DETAILS****B. MARSHALL MARINE LTD.****INSTALLATION ADDRESS****D.S.V. CURTIS - MARSHALL (DIVE Support VESSEL).****DESCRIPTION AND EXTENT OF THE INSTALLATION**

✓ tick boxes as appropriate

New installation ☒Addition to an existing installation ☐Alteration to an existing installation ☐Description of installation: **ENGINE ROOM MAIN CONTROL PANEL**Extent of installation work covered by this certificate: **MAIN CONTROL 415V - 3 PHASE DISTRIBUTION TO VARIOUS EQUIPMENT.****DESIGN**

I/We* being the person(s) responsible for the design of the electrical installation (as indicated by my/our* signature(s) below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design hereby CERTIFY that the design work for which I/we* have been responsible is to the best of my/our* knowledge and belief in accordance with BS 7671: 2008 amended to (date) except for the departure(s), if any, details as follows:

Details of departure(s) from BS 7671:

NONE

The extent of liability of the signatory or the signatories is limited to the work described above as the subject of this certificate.

For the DESIGN of the installation:

Designer (No.1) - Signature

C. Jakeman

Name (BLOCK LETTERS)

C. JAKEMAN

Date

12/06/2014

Designer (No.2) - Signature

A. Norris

Name (BLOCK LETTERS)

A. NORRIS

Date

12/06/2014**CONSTRUCTION**

I/We* being the person(s) responsible for the construction of the electrical installation (as indicated by my/our* signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the construction hereby CERTIFY that the construction work for which I/we* have been responsible is to the best of my/our* knowledge and belief in accordance with BS 7671: 2008 amended to (date) except for the departure(s), if any, details as follows:

Details of departure(s) from BS 7671:

The extent of liability of the signatory or the signatories is limited to the work described above as the subject of this certificate.

For the CONSTRUCTION of the installation:

Constructor(s) - Signature(s)

A. Norris

Name(s) (BLOCK LETTERS)

A. NORRIS

Date

18/06/2014**INSPECTION & TESTING**

I/We* being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our* signature(s) below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby CERTIFY that the inspection and testing work for which I/we* have been responsible is to the best of my/our* knowledge and belief in accordance with BS 7671: 2008 amended to (date) except for the departure(s), if any, details as follows:

Details of departure(s) from BS 7671:

The extent of liability of the signatory or the signatories is limited to the work described above as the subject of this certificate.

For the INSPECTION AND TESTING of the installation:

Inspector(s) - Signature(s)

A. Norris

Name(s) (BLOCK LETTERS)

A. NORRIS

Date

8th/01/2015**NEXT INSPECTION**

I/We* the designer(s), recommend that this installation is further inspected and tested after an interval of not more than

YEARS

5

MONTHS

0

ELECTRICAL INSTALLATION CERTIFICATE

REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS 7671 (IEE Wiring Regulations)

Page 2 of

5

CERT No:

DSV 05**DESIGNER (No.1)**

Name: **C. JAKEMAN**
Company: **B. MARSHALL MARINE LTD.**
Address: **DOCKSIDE ROAD,**
MIDDLESBROUGH.
Postcode: **TS3 8AT** Phone No: **01642 211234**

DESIGNER (No.2)

Name: **A. NORRIS**
Company: **YARM ELECTRICAL SERVICES**
Address: **29 ROUNDHAY DRIVE,**
EAGLESCUPPE.
Postcode: **TS16 9HW** Phone No: **01642-787502**

CONSTRUCTOR(S)

Name(s): **A. NORRIS / K. JONES.**
Company: **YARM ELECTRICAL SERVICES.**
Address: **29 ROUNDHAY DRIVE,**
EAGLESCUPPE.
Postcode: **TS16 9HW** Phone No: **01642-787502**

INSPECTOR(S)

Name(s): **A. NORRIS**
Company: **YARM ELECTRICAL SERVICES**
Address: **29 ROUNDHAY DRIVE,**
EAGLESCUPPE.
Postcode: **TS16 9HW** Phone No: **01642-787502**

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

✓ tick box where applicable

Number of Live Conductors 2/3/4*	Type of live conductors: a.c. / d.c.	
Nature of Supply	Nominal voltage: U 238 (V) U ₀ 418 (V)	Nominal frequency (f): 50 Hz
	Fault current (earth fault/short-circuit) 0.4 kA	External loop impedance (Z _e): 0.72 Ω
Supply Protective Device Characteristics:	BS (EN):	Rated Current/Current Setting (In) A
Earthing Arrangements:	TN-S <input checked="" type="checkbox"/> TN-C-S <input type="checkbox"/> TT <input type="checkbox"/> TN-C <input type="checkbox"/> IT <input type="checkbox"/>	

PARTICULARS OF INSTALLATION REFERRED TO IN THE CERTIFICATE

Maximum

✓ tick box where applicable

Means of Earthing: Distributor's facility ☒ Installation earth electrode ☐ demand (load): **14A** Amps per phase

Details of Installation Earth Electrode

Location: Type (rods, etc.):

Electrode Resistance to Earth (R_e): Ω Method of Measurement:

Main Protective Conductors

✓ tick box where applicable

Earthing Conductor:	Material: Copper c.s.a: 70.0 mm ²	Connection(s) verified: <input checked="" type="checkbox"/>
Protective Bonding Conductors:	Material: Copper c.s.a: 95.0 mm ²	Connection(s) verified: <input checked="" type="checkbox"/>

To: Water Installation Pipe ☐ Gas Installation Pipe ☐ Other Elements ☒ **STRUCTURE**

Main Switch or Circuit-breaker Location: **MAIN CONTROL PANEL**

BS (EN), type and No. of poles **4 pole** Current rating: A Fuse rating or setting: Voltage rating: **500** V

Rated residual operating current I_n: mA Operating time at I_n: ms

COMMENTS ON EXISTING INSTALLATION**SCHEDULE(S)**

THE ATTACHED SCHEDULES ARE PART OF THIS DOCUMENT AND THIS CERTIFICATE IS VALID ONLY WHEN THEY ARE ATTACHED TO IT.

No. of Schedules of Inspections attached: **1** No. of Schedules of Test Results attached: **1**

The safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed and inspected and tested in accordance with BS 7671: 2008 (the IEE Wiring Regulations).

The recipient should receive the 'original' certificate and a duplicate should be retained by the contractor. In the event that you are the person ordering or acting on behalf of the owner, this certificate or a copy of it should be passed to the owner immediately. The 'original' certificate should be kept in a safe place and should be

shown to any person carrying out work on or inspecting this installation in the future.

For safety reasons this electrical installation needs to be re-inspected by a competent person at appropriate intervals. Under the section 'Next Inspection' of this certificate is stated the maximum time interval recommended before the next inspection.

The Construction (Design and Management) Regulations require for an installation covered by these Regulations, that a copy of this

certificate together with the relevant schedules of inspection and test results are included in the project health and safety documentation.

This certificate is only intended to be issued for a new installation or for new work carried out on or associated with the alteration or addition to an existing installation.

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERT / REPORT
SCHEDULE NO

DSV 05

Location: DSV - CURTIS - MARSHALL Date: 8th - JAN - 2015

Designation: MAIN PANEL 415 V - 3 PHASE DISTRIBUTION

Inspected and tested by: (Print and sign)

Name: A. NORRIS

Signature: A.G. Norris

System Characteristics

System type:

TN-C-S ☐ TN-S ☒ TT ☐

[Tick relevant box(es)]

Fault level(s):

1 ϕ kA

3 ϕ 0.72 kA

Measured impedance at dis. board/consumer unit Z_g/Z_s : 0.4 Ω

Main Switch

Supply polarity confirmed: ☒ (✓)

Make: BS (EN):

Voltage rating: 500 V Current rating (I_n): A

(If) RCD: mA Operation time (at $I_{\Delta n}$): ms

DB/CU supplied from: (A) SHORE SUPPLY
(B) GENERATORS

Equipment vulnerable to testing:

SYSTEM MONITORING EQUIPMENT

Supply Protective Device Details

BS (EN): Current rating (I_n): A (If) RCD: $I_{\Delta n}$: mA Operating time at $I_{\Delta n}$: ms

CIRCUIT DETAILS

TEST RESULTS

Number of ways	Circuit description	Type of wiring (e.g. PVC/PVC)	Number of points served	Circuit conductors [mm ²]		Max disconnection time (s) permitted by BS 7671	Overcurrent protective devices				RCD	Circuit impedances (Ω)			Insulation resistance (MΩ)			Polarity (✓)	Maximum measured earth fault loop impedance, Z _e (Ω)	RCD operating times (ms)				
				Lws	cpc		BS (EN)	Type	Rating (A)	Fault current capacity (kA)		Operating current I _{Δn} (mA)	Ring final circuits only			All circuits	Between live conductors			Line(s)/Earth	Neutral/Earth	at I _{Δn}	at 5I _{Δn} (if applicable)	
													F ₁	F ₂	F ₃									R ₁ - R ₂ or R ₂ - R ₃
	L.P. COMPRESSOR	PVC/dry	1	16.0	16.0		6883	FUSE	63	20					0.07	≥200	≥200		✓					
	" " "														0.07	≥200	≥200							
	" " "														0.07	≥200	≥200							
	H.P. COMPRESSOR	PVC/dry	1	16.0	16.0		6883	FUSE	63	20					0.05	≥200	≥200		✓					
	" " "														0.05	≥200	≥200							
	" " "														0.5	≥200	≥200							
	BLACK WATER PUMP	PVC/on		2.5	2.5		6883	FUSE	16	20					0.10	≥200	≥200		✓					
	" " "														0.10	≥200	≥200							
	" " "														0.10	≥200	≥200							
	GREY WATER PUMP.	PVC/on		2.5	2.5		6883	FUSE	16	20					0.10	≥200	≥200		✓					
															0.10	≥200	≥200							
															0.10	≥200	≥200							

TEST INSTRUMENTS USED	Make Model Serial Number	Multi-functional:	Insulation resistance: ROBIN KMP 3030 41211 90	Continuity: ROBIN KMP 3050 41214 90	Earth electrode resistance:	Earth fault loop impedance: ROBIN KMP 4120 41258 59	RCD: ROBIN KMP 5404 2366318
-----------------------	--------------------------	-------------------	--	-------------------------------------	-----------------------------	---	-----------------------------

Deviations from BS 7671: 2008:

and further comments:

SCHEDULE OF INSPECTIONS

5

Page **5** of **5**

CERT/REPORT
SCHEDULE NO.

DSV 02

Methods of protection against electric shock

Both basic and fault protection:

- ☒ (i) SELV
- ☒ (i) PELV
- ☐ (iii) Double insulation
- ☒ (iv) Reinforced insulation

Basic protection:

- ☒ (i) Insulation of live parts
- ☒ (i) Barriers or enclosures
- ☒ (iii) Obstacles
- ☒ (iv) Placing out of reach

Fault protection

(i) Automatic disconnection of supply:

- ☒ Presence of earthing conductor
- ☒ Presence of circuit protective conductors
- ☒ Presence of protective bonding conductors
- ☒ Presence of supplementary bonding conductors
- ☒ Presence of earthing arrangements for combined protective and functional purposes
- ☒ Presence of adequate arrangements for alternative source[s], where applicable
- ☒ FELV
- ☒ Choice and setting of protective and monitoring devices (for fault and/or overcurrent protection)

(ii) Non-conducting location:

- ☒ Absence of protective conductors

(iii) Earth-free local equipotential bonding:

- ☒ Presence of earth-free local equipotential bonding

(iv) Electrical separation:

- ☒ Provided for **one** item of current-using equipment
- ☒ Provided for **more than one** item of current-using equipment

Additional protection:

- ☒ Presence of residual current device(s)
- ☒ Presence of supplementary bonding conductors

☒ To indicate an inspection has been carried out and the result is satisfactory.

Prevention of mutual detrimental influence

- ☒ (a) Proximity of non-electrical services and other influences
- ☒ (b) Segregation of Band I and Band II circuits or use of Band II insulation
- ☒ (c) Segregation of safety circuits

Identification

- ☒ (a) Presence of diagrams, instructions, circuit charts and similar information
- ☒ (b) Presence of danger notices and other warning notices
- ☒ (c) Labelling of protective devices, switches and terminals
- ☒ (d) Identification of conductors

Cables and conductors

- ☒ Selection of conductors for current-carrying capacity and voltage drop
- ☒ Erection methods
- ☒ Routing of cables in prescribed zones
- ☒ Cables incorporating earthed armour or sheath or run within an earthed wiring system, or otherwise adequately protected against nails, screws and the like
- ☒ Additional protection provided by 30 mA RCD for cables concealed in walls (where required in premises not under the supervision of a skilled or instructed person)
- ☒ Connection of conductors
- ☒ Presence of fire barriers, suitable seals and protection against thermal effects

General

- ☒ Presence and correct location of appropriate devices for isolation and switching
- ☒ Adequacy of access to switchgear and other equipment
- ☒ Particular protective measures for special installations and locations
- ☒ Connection of single-pole devices for protection or switching in line conductor[s] only
- ☒ Correct connection of accessories and equipment
- ☒ Presence of undervoltage protective devices
- ☒ Selection of equipment and protective measures appropriate to external influences
- ☒ Selection of appropriate functional switching devices

☒ To indicate an inspection is not applicable.

In addition to the above, the following notations may also be used when reporting on existing installations:

☒ To indicate an inspection has been carried out and the result is unsatisfactory.

Lim Indicates that, exceptionally, a limitation agreed with the person ordering the work prevented the inspection being carried out.

Inspected by (print and sign):

A. NORRIS *AG Norris*

Date:

8th JAN
2015