

Electrical Equipment

Note: This does not include equipment such as lighting or power sockets which form part of a vessel or platform electrical system

When new

Examination/Test	Category of Competent Person
In accordance with manufacturer's specification and fit for the purpose it will be used for	3 or 4

When in service

Examination/Test	Validity Period	Category of Competent Person
Visual examination, function test of unit (including protective devices) plus continuity and resistance testing of any cables Note: Any certificate issued should clearly identify the various sub-systems and items included in the test	6 months	2, 3 or 4

Reference:

- ♦ IMCA D 045 – *Code of practice for the safe use of electricity under water*