



Planned Maintenance Information

Uninterrupted Power Supply unit

Make:

Ref	Task No.	Maintenance Guide	Frequency
			6 Monthly
A	1	General Visual Inspection	
	2	Run up, cut main power and function check UPS and all items powered by unit	
	3	Check battery and Charge if necessary	
	4	PAT Test charging unit	
	5	Re-certify	

REMEMBER TO UPDATE ALL RELEVANT FOLDERS

Notes :

1. Provision and Use of Work Equipment Regulations 1998 Apply
2. It is important (whenever possible) that the unit be kept as dry as possible in order to reduce ingress of water into the unit and slow down the incidence of corrosion to switches and electrical connectors